



# Office of General Services

DESIGN & CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242

---

## ADDENDUM NO. 2 TO PROJECT NO. 46121

CONSTRUCTION, HVAC, PLUMBING AND ELECTRICAL WORK  
PROVIDE WET LAB, 6<sup>TH</sup> FLOOR, BUILDING 4  
NEW YORK PSYCHIATRIC INSTITUTE  
1051 RIVERSIDE DRIVE  
NEW YORK, NY

July 10, 2025

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

### HVAC WORK DRAWINGS:

1. Drawing No. M-208:
  - a. GENERAL NOTES, Change Note 1 to read:

“1. REPLACE/RECONNECT TO EXISTING (8) EXHAUST FANS, ...”
2. Drawing No. M-701, M-702, M-703, M-704 and M-705:
  - a. Add the following Notes:
    - “1. CONTRACTOR TO PROVIDE ALL WIRING AND CONDUIT FOR CONTROL WORK.
    2. SIEMENS PROPOSAL ATTACHED TO PROJECT MANUAL FOR CONTROL WORK TO BE PROVIDED BY SIEMENS BY SPECIFIC ALLOWANCE.”

**END OF ADDENDUM**

Brady M. Sherlock, P.E.  
Director, Division of Design  
Design & Construction