



# Office of General Services

DESIGN & CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242

---

## ADDENDUM NO. 5 TO PROJECT NO. 47082

CONSTRUCTION AND ELECTRICAL WORK  
REHABILITATE WATER FILTRATION PLANT  
ADIRONDACK CORRECTIONAL FACILITY  
196 RAY BROOK ROAD  
RAY BROOK, NY

March 25, 2026

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

### ELECTRICAL WORK DRAWINGS

1. Drawing No. E-009:
  - a. Drawing No. E-009, Detail 7, Duct Bank Notes – Revise Notes 1 and 2 to Read:
    - “1. CONCRETE ENCASED DUCTBANK INCLUDES ALL AREAS NORMALLY SUBJECT TO VEHICULAR TRAFFIC, AND OTHER AREAS AS SHOWN ON THE PLANS. ASPHALT RESTORATION IS IN ACCORDANCE WITH DETAIL 8 OF THIS SHEET.”
    - “2. DUCTBANKS WILL BE CONCRETE ENCASED UNDER ALL PAVED SURFACES, AS SHOWN ON PLANS, AND EXTENDING 5' BEYOND PAVED AREAS.”

### END OF ADDENDUM

Brady M. Sherlock, P.E.  
Director, Division of Design  
Design & Construction