



DESIGN & CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242

ADDENDUM NO. 1 TO PROJECT NO. 47275

**HVAC AND ELECTRICAL WORK
REPLACE BOILERS, BUILDING 29 & 31, AND PROVIDE HVAC/PLUMBING
MODIFICATIONS, BUILDING 66 AND 90
INDUSTRY LIMITED SECURE CENTER
375 RUSH SCOTTSVILLE ROAD, RUSH, NY**

November 2, 2023

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

ELECTRICAL WORK

1. Page 283105– Page 4-5, Article 2.01, B, CHANGE Paragraph to read:

“B. Carbon Monoxide Sensors:

1. General: Include the following features:
 - a. Provide Monitor module for connection to existing fire alarm system
 - b. Long 10-year sensor life
 - c. Advanced electrochemical carbon monoxide sensing technology
 - d. Ground fault detection by module
 - e. Non-volatile memory
 - f. Bicolor (green/red) status LED
 - g. Standard, relay, fault isolator, and audible alarm.”

END OF ADDENDUM

Brady M. Sherlock, P.E.
Director, Division of Design
Design & Construction