



DESIGN & CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242

---

**ADDENDUM NO. 2 TO PROJECT NO. 47349**

**CONSTRUCTION WORK  
PROVIDE 5<sup>th</sup> FLOOR CONFERENCE ROOM  
DEPARTMENT OF LABOR, BUILDING NO. 12  
STATE OFFICE BLDG CAMPUS  
ALBANY, NY**

July 3, 2024

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**GENERAL REQUIREMENTS**

1. Page 015000 -4 Paragraph 1.11.C: CHANGE Paragraph to Read:

“C. Limited parking (up to 5 vehicles) will be permitted at any time subject to proper campus registration of the vehicles at a location determined by the Director’s Representative.”

**CONSTRUCTION DRAWINGS**

2. Drawing No. A-101:

a. KEYNOTES, CHANGE Keynote 12 to Read:

“12. REMOVE AND DISPOSE OF DRINKING FOUNTAIN. CAP EXISTING SUPPLY AND SANITARY PIPING.”

3. Drawing No. A-102:

a. KEYNOTES, CHANGE Keynote 16 to Read:

“12. PROVIDE ELKAY MODEL LZS8WSSP, SINGLE ADA ELECTRIC WATER COOLER WITH ezH20 BOTTLE FILLER AND MODEL MLP100 IN-WALL CARRIER FOR SINGLE-STATION ON-WALL BOTTLE FILLERS COOLERS & FOUNTAINS (OR APPROVED EQUAL). EXTEND DOMESTIC COLD WATER AND SANITARY PIPING FROM CAPPED LOCATION OF REMOVED WATER COOLER TO THIS LOCATION AND ATTACH TO EWC. PIPING CONNECTED TO SHALL BE OF EQUAL OR GREATER SIZE. FIELD VERIFY EXACT TIE-IN LOCATION. COORDINATE ELECTRICAL POWER SUPPLY IN THE FIELD.”

**END OF ADDENDUM**

Brady M. Sherlock, P.E.  
Director, Division of Design  
Design & Construction