

DESIGN & CONSTRUCTION GROUP THE GOVERNOR NELSON A. ROCKEFELLER EMPIRE STATE PLAZA ALBANY, NY 12242

ADDENDUM NO. 3 TO PROJECT NO. 47479

CONSTRUCTION AND ELECTRICAL WORK RENOVATE LOADING DOCK & BUILDING ENTRANCE E ROOSEVELT STATE OFFICE BUILDING 4 BURNETT BLVD POUGHKEEPSIE, NEW YORK

March 28, 2025

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

BIDDING REQUIREMENTS

1. DOCUMENT 001114 ADVERTISEMENT FOR BIDS: The last date for receipt of bids is changed from Wednesday, April 2, 2025, to Wednesday, April 16, 2025.

CONSTRUCTION WORK DRAWINGS

- 2. Drawing No. S-101:
 - a. DETAIL 1/S-101, KEYNOTES, Change Note 7. To Read:
 - "7. REMOVE EXISTING 4" CMU WALL AND 4" BRICK VENEER WHERE INDICATED. REFER TO ARCHITECTURAL DRAWINGS FOR ADDITIONAL INFORMATION."
- 3. Drawing No. S-501:
 - a. DETAIL 2/S-501, Add the following Note:

"PROVIDE SUBBASE COURSE TYPE 2 8" THICK PER DETAIL 1/S-501. REFER TO SPECIFICATION SECTION 072600 FOR INFORMATION REGARDING THE VAPOR BARRIER BELOW THE SLAB ON GRADE."

END OF ADDENDUM

Brady Sherlock, P.E. Director, Division of Design Design & Construction