



# Office of General Services

DESIGN & CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242

---

## ADDENDUM NO. 2 TO PROJECT NO. 47574

CONSTRUCTION, HVAC, AND ELECTRICAL WORK  
PROVIDE AUTOMATED RECORD FIRE RANGE  
CAMP SMITH TRAINING SITE  
11 BEAR MOUNTAIN BRIDGE ROAD  
CORTLANDT MANOR, NY

July 24, 2025

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

### ELECTRICAL WORK SPECIFICATIONS

1. SECTION 271005 STRUCTURE CABLING FOR VOICE AND DATA, Article 2.04, Paragraph A:  
Add the following subparagraph:
  - “2. In harsh-condition applications Provide NFPA 70 type CMG armored cable. Belden p/n #127953A.”

**END OF ADDENDUM**

Brady M. Sherlock, P.E.  
Director, Division of Design  
Design & Construction