



Office of General Services

DESIGN & CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242

ADDENDUM NO. 2 TO PROJECT NO. 47655

CONSTRUCTION WORK REPLACE WATER & SEPTIC SYSTEM DOT REGION 9, CHENANGO COUNTY ROUTE 206 BAINBRIDGE, NY

May 29, 2026

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATIONS

1. SECTION 023313 UNDERGROUND UTILITY LOCATOR SERVICE, Subparagraph 1.4.A. 1.a: Change subparagraph to read:

"a. Contractor shall include 16 hours of Level A locator service to locate underground utilities as identified on the contract drawings or as identified during the Level B investigation that require more specific location, invert elevation, size, etc. Level A investigation shall only be performed at identified locations or as directed."

2. SECTION 330507.13 UTILITY DIRECTIONAL DRILLING, Subparagraph 1.1.B: Change subparagraph to read:

"B. Related Requirements:

- " 1. Section 036000 - Grouting: Filling of abandoned boreholes.
2. Section 310001 - Soils for Earthwork: Subsoil fill as required by this Section.
3. Section 310000 - Excavation, Trenching, & Fill: Excavation of subsoil, trenching, and installation and compaction requirements as required by this Section.
4. Section 330505.31 - Hydrostatic Testing: Sanitary sewer pipe testing.
5. Section 330505.33 - Infiltration and Exfiltration Testing: Sanitary sewer pipe testing.
6. Section 330597 - Identification and Signage for Utilities: Underground pipe markers.
7. Section 331413 - Public Water Utility Distribution Piping: Potable-water pipe testing.
8. Section 331417 - Site Water Service Utility Laterals: Potable-water pipe testing."

DRAWINGS

3. Drawing No. C-511:
 - a. WELL DECOMMISSIONING AND ABANDONMENT NOTES, Add the following Note:

“14. DEPTH OF THE WATER WELL SERVING THE GARAGE BUILDING IS PURPORTEDLY 300 FEET BELOW GRADE. DEPTH THE OTHER FACILITY WELL IS PURPORTEDLY 530 FEET BELOW GRADE. CASING DIAMETER FOR EACH WELL IS 6 INCHES.”

END OF ADDENDUM

Brady M. Sherlock, P.E.
Director, Division of Design
Design & Construction