



Office of General Services

DESIGN & CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242

ADDENDUM NO. 2 TO PROJECT NO. M3212

HVAC AND ELECTRICAL WORK REPLACE CHILLER UNITS, HOSPITAL BUILDING 156 CLINTON CORRECTIONAL FACILITY ROUTE 374 COOK STREET DANNEMORA, NY

April 4, 2025

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

HVAC WORK DRAWINGS

1. Drawing M-101:
 - a. GENERAL NOTES, Add the following Note:
 - “4. PROVIDE 1” THICK MINERAL FIBER BLANKET OR PREFORMED INSULATION AT PLATE AND FRAME HEAT EXCHANGERS, BUFFER TANK, AIR SEPARATOR AND CHILLED WATER PUMPS. INSTALL PER SPECIFICATION SECTION 230719 3.5.”

END OF ADDENDUM

Brady M. Sherlock, P.E.
Director, Division of Design
Design & Construction