



Office of General Services

DESIGN & CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242

ADDENDUM NO. 2 TO PROJECT NO. Q1851

**CONSTRUCTION WORK
PROVIDE PAVING & SITE PIPING IMPROVEMENTS,
BUILDINGS 26, 47, 56, 69, 71 & 72
PILGRIM PSYCHIATRIC CENTER
998 CROOKED HILL ROAD
WEST BRENTWOOD, NY**

December 6, 2024

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONSTRUCTION WORK DRAWINGS

1. Drawing Nos. C-004, C-005, C-006, C-007 and C-008:
 - a. Add the following:

“SEQUENCING NOTES:

1. Recommended construction phase sequencing is shown. The final sequence of construction phases may be modified with approval from the Director’s Representative.
2. Phase boundaries shown may be modified to better suit existing site conditions and stormwater or sanitary sewer flows with approval from the Director’s Representative.
3. Provide bypass pumping for stormwater and sanitary sewer flows required for the work of the contract in accordance with Section 015720. For bidding purposes, assume use of a pump with minimum flow rate of 100 GPM, maximum flow rate of 500 GPM.
4. Complete work of each phase, including asphalt top course, striping and signage before commencing work of subsequent phase. Removal of temporary construction fence must be removed promptly upon acceptance of completed work by the Director’s Representative.”

END OF ADDENDUM

Brady Sherlock, P.E.
Director, Division of Design
Design & Construction