



Office of General Services

DESIGN & CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242

ADDENDUM NO. 2 TO PROJECT NO. Q1869

CONSTRUCTION WORK REPLACE SEWER OUTFALL PIPE GREEN HAVEN CORRECTIONAL FACILITY ROUTE 216 STORMVILLE, NY

May 13, 2025

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

DRAWINGS

1. Drawing No. G-002
 - a. BYPASS PUMPING OF SEWER FLOWS, Add the following Note:
 - “2. The average flow through the existing sewer main outfall is approximately 300,000 gallons per day.”

END OF ADDENDUM

Brady M. Sherlock, P.E.
Director, Division of Design
Design & Construction