

DESIGN & CONSTRUCTION GROUP THE GOVERNOR NELSON A. ROCKEFELLER EMPIRE STATE PLAZA ALBANY, NY 12242

ADDENDUM NO. 1 TO PROJECT NO. Q1882

HVAC, FIRE PROTECTION AND ELECTRICAL WORK REMOVE FIRE SUPPRESSION SYSTEMS, VARIOUS LOCATIONS VARIOUS ITS FACILITIES

October 17, 2025


NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

ELECTRICAL WORK DRAWINGS

- 1. Revised Drawings:
 - a. Drawing Nos. E-101 & ED-501 noted "REVISED DRAWING 10/17/25" accompany this Addendum and supersede the same numbered originally issued drawings.

END OF ADDENDUM

Brady M. Sherlock, P.E. Director, Division of Design Design & Construction



SHEET GENERAL NOTES

- 1. PARTIAL ELECTRICAL PLAN IS SHOWN. ALL EQUIPMENT AND LOADS NOT SHOWN ARE TO REMAIN UNLESS OTHERWISE NOTED.
- 2. TESTING OF PAINTED BUILDING COMPONENTS HAS BEEN PERFORMED AND CONFIRMS THE PRESENCE OF LEAD BASED PAINT FOR THE BATTERY RACK . ALL THE PAINTED BATTERY RACK COMPONENTS SHALL BE ASSUMED TO BE COATED WITH LEAD BASED PAINT AND HANDLED ACCORDINGLY.
- 3. COMPLY WITH OSHA 29 1926.62: LEAD EXPOSURE IN CONSTRUCTION: INTERIM FINAL RULE FOR ALL ACTIVITIES WHICH AN EMPLOYEE MAY BE OCCUPATIONALLY EXPOSED TO LEAD.
- 4. REMOVE, CONTAIN, CAPTURE, COLLECT, AND DISPOSE OF ALL PAINTED BUILDING COMPONENTS THAT WILL BE REMOVED OR DISTURBED AS PART OF THIS PROJECT IN COMPLIANCE WITH ALL CURRENT AND PENDING FEDERAL AND STATE REGULATIONS.
- 5. REFER TO SPECIFICATION SECTIONS 028303 AND 028304 FOR ADDITIONAL REQUIREMENTS.

SHEET KEYNOTES

- 1. BATTERY BANK CONSISTS OF 48 TYCO AVR BATTERIES, MODEL: AVR 95-33. REMOVE AND PROPERLY DISPOSE OF ALL BATTERIES AND ASSOCIATED EQUIPMENT. REFER TO PARTIAL SINGLE LINE DIAGRAM - REMOVAL ON SHEET E-102 FOR ADDITIONAL INFORMATION.
- 2. REFER TO PARTIAL SINGLE LINE DIAGRAM ON SHEET E-102 FOR CONDUIT AND WIRE REQUIREMENTS BETWEEN PANEL 'EL-LP-B-1,' AND 'INVERTER OUTPUT PANEL'.
- 3. H-CONTRACTOR IS RESPONSIBLE FOR REMOVAL OF INDICATED AIR HANDLING UNITS. E-CONTRACTOR SHALL REMOVE ELECTRICAL EQUIPMENT AND ALL ASSOCIATED CONDUCTORS, CABLES, FITTINGS, SUPPORTS, AND HARDWARE. ABANDON AND CAP ALL UNDERGROUND CONDUITS AND CONDUITS CONCEALED IN CEILING. REMOVE ALL EXPOSED CONDUITS. EQUIPMENT IS FED FROM BREAKERS IN PANEL 'EL-LP-B-1.' BREAKERS TO REMAIN, RE-LABEL TO INDICATE 'SPARE.'



DESIGN & CONSTRUCTION

CONSULTANT

CERTIFICATE OF AUTHORIZATION #: 018416



GHD Consulting Services Inc.

THE ALTERATION OF THIS MATERIAL IN ANY WAY, UNLESS DONE UNDER THE DIRECTION OF A COMPARABLE PROFESSIONAL, I.E. ARCHITECT FOR AN ARCHITECT, ENGINEER FOR AN ENGINEER OR LANDSCAPE ARCHITECT FOR A LANDSCAPE ARCHITECT, IS A VIOLATION OF THE NEW YORK STATE EDUCATION LAW AND/OR REGULATIONS AND IS A CLASS 'A' MISDEMEANOR.



REMOVE FIRE SUPPRESSION SYSTEMS VARIOUS LOCATIONS

VARIOUS ITS FACILITIES ALBANY, NY

OFFICE OF INFORMATION TECHNOLOGY SERVICES

03/17/2025 BID DOCUMENTS DESCRIPTION Q1882 — E NUMBER: DESIGNED BY: FIELD CHECK: APPROVED:

> ALFRED E. SMITH PARTIAL BASEMENT ELECTRICAL PLAN

DRAWING NUMBER:

E - 101

REA OF WORK KEY PLAN

SCALE: NTS

SHEET GENERAL NOTES

- 1. PARTIAL REMOVALS PLAN IS SHOWN. ALL EQUIPMENT AND LOADS NOT SHOWN ARE TO REMAIN UNLESS OTHERWISE NOTED.
- 2. TESTING OF PAINTED BUILDING COMPONENTS HAS BEEN PERFORMED AND CONFIRMS THE PRESENCE OF LEAD BASED PAINT. ALL PAINT BUILDING COMPONENTS SHALL BE ASSUMED TO BE COATED WITH LEAD BASED PAINT AND HANDLED ACCORDINGLY.
- 3. COMPLY WITH OSHA 29 1926.62: LEAD EXPOSURE IN CONSTRUCTION: INTERIM FINAL RULE FOR ALL ACTIVITIES WHICH AN EMPLOYEE MAY BE OCCUPATIONALLY EXPOSED TO LEAD.
- 4. REMOVE, CONTAIN, CAPTURE, COLLECT, AND DISPOSE OF ALL PAINTED BUILDING COMPONENTS THAT WILL BE REMOVED OR DISTURBED AS PART OF THIS PROJECT IN COMPLIANCE WITH ALL CURRENT AND PENDING FEDERAL AND STATE REGULATIONS.
- 5. REFER TO SPECIFICATION SECTIONS 028303 AND 028304 FOR ADDITIONAL REQUIREMENTS.

SHEET KEYNOTES

1. H-CONTRACT IS RESPONSIBLE FOR REMOVAL OF INDICATED EXHAUST FANS, LIEBERT UNITS, CONDENSING UNITS, AND AIR CONDITIONING UNITS. E-CONTRACTOR SHALL REMOVE ELECTRICAL EQUIPMENT AND ALL ASSOCIATED CONDUCTORS, CABLES, FITTINGS, SUPPORTS, AND HARDWARE. ABANDON AND CAP ALL UNDERGROUND CONDUITS AND CONDUITS CONCEALED IN CEILING. REMOVE ALL EXPOSED CONDUITS. EQUIPMENT IS FED FROM BREAKERS IN PANEL 'LP-TEL-7.' BREAKERS TO REMAIN, RE-LABEL TO INDICATE 'SPARE.'



DESIGN & CONSTRUCTION

CONSULTANT


CERTIFICATE OF AUTHORIZATION #: 018416



GHD Consulting Services Inc.

WARNING:


THE ALTERATION OF THIS MATERIAL IN ANY WAY, UNLESS DONE UNDER THE DIRECTION OF A COMPARABLE PROFESSIONAL, I.E. ARCHITECT FOR AN ARCHITECT, ENGINEER FOR AN ENGINEER OR LANDSCAPE ARCHITECT FOR A LANDSCAPE ARCHITECT, IS A VIOLATION OF THE NEW YORK STATE EDUCATION LAW AND/OR REGULATIONS AND IS A CLASS 'A' MISDEMEANOR.



REMOVE FIRE SUPPRESSION SYSTEMS VARIOUS LOCATIONS

LOCATION: VARIOUS ITS FACILITIES ALBANY, NY

OFFICE OF INFORMATION TECHNOLOGY SERVICES



HARRIMAN CAMPUS STATE OFFICE BUILDING 7 PARTIAL BASEMENT ELECTRICAL REMOVALS PLAN

DRAWING NUMBER:

AREA OF WORK

KEY PLAN

SCALE: NTS

ED-501

or 49

REVISED DRAWING 10/17/2025