



# Office of General Services

DESIGN & CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242

---

## ADDENDUM NO. 1 TO PROJECT NO. Q1934

### CONSTRUCTION WORK REPAIR AND PAVE ROADWAYS INDUSTRY LIMITED SECURE FACILITY 375 RUSH SCOTTSVILLE ROAD RUSH, NY

March 21, 2025

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

#### SPECIFICATIONS

1. SECTION 260519 - LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES, Subparagraph 3.7 A.1.: Delete this Subparagraph in its entirety.
2. SECTION 260519 - LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES, Subparagraph 3.7 A.2.: Delete this Subparagraph in its entirety.
3. SECTION 260519 - LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES, Subparagraph 3.7 A.3.: Delete this Subparagraph in its entirety.
4. SECTION 260519 - LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES, Subparagraph 3.7 A.4.: Change Subparagraph to read:
  - “4. Administer and perform tests and inspections with assistance of a Company Service Advisor or a factory-authorized service representative.”.
5. SECTION 260543 - UNDERGROUND DUCTS AND RACEWAYS FOR ELECTRICAL SYSTEMS, Paragraph 1.5 A.: Change Paragraph to read:
  - “A. Furnish cable-support stanchions, arms, insulators, and associated fasteners in quantities equal to 10 percent of quantity of each item installed.”.

6. SECTION 265613 - LIGHTING POLES AND STANDARDS, Paragraph 1.6 A.: Change Paragraph to read:
  - “A. Pole repair materials, to include paint, handhold cover, mounting hardware, gaskets, associated fasteners, and other repair materials as recommended by the manufacturer.”.
7. SECTION 265613 - LIGHTING POLES AND STANDARDS, Paragraph 3.7 A.: Change Paragraph to read:
  - “A. Inspections: In the presence of the Director’s Representative, perform the following inspections:”.
8. SECTION 265619 - LED EXTERIOR LIGHTING, Paragraph 1.4. N.: Change Paragraph to read:
  - “N. Product Test Reports: For each luminaire, for tests performed by manufacturer.”.
9. SECTION 265619 - LED EXTERIOR LIGHTING, Article 3.7: Delete this Article in its entirety.
10. SECTION 312500 - EROSION AND SEDIMENTATION CONTROLS, Paragraph 1.8. A.: Change Paragraph to read:
  - “A. Adhere to all erosion and sediment control requirements presented in the contract Drawings. Comply with all applicable NYSDEC regulatory requirements.”.
11. SECTION 329200 - TURF AND GRASSES, Paragraph 1.4 A.: Delete this Paragraph in its entirety.
12. SECTION 334200 - STORMWATER CONVEYANCE, Subparagraphs 3.7 B.2.: Delete this Subparagraph in its entirety.
13. SECTION 334200 - STORMWATER CONVEYANCE, Subparagraph 3.7 B.3.: Delete this Subparagraph in its entirety.
14. SECTION 334200 - STORMWATER CONVEYANCE, Subparagraph 3.7 B.4.: Delete this Subparagraph in its entirety.

**DRAWINGS**

15. Drawing No. C-132:
  - a. DRAWING NOTES: Change Note 8. to read:

“8. Raise existing catch basin rim to match grade per Detail 5/C-504.”.
16. Drawing No. E-501:
  - a. DETAIL 2/E-04, TYPICAL LIGHT POLE DETAIL: Change “CONDUITS, SEE ADDENDUM DWG. C1.04ADD2-A FOR SIZE AND QUANTITY” to read “CONDUITS”.

**END OF ADDENDUM**

Brady M. Sherlock, P.E.  
Director, Division of Design  
Design & Construction